



ÚJD SR  
Bajkalská 27  
P.O.Box 24  
820 07 Bratislava

Contact: Mag. Agnes Zauner  
GLOBAL 2000 – Friends of the Earth Austria  
Neustiftgasse 36  
1070 Wien

via Email to [Imrich.Smrtnik@ujd.gov.sk](mailto:Imrich.Smrtnik@ujd.gov.sk)

June 10<sup>th</sup> 2021

## **GLOBAL 2000 Second Appeal Against the First Degree Decision ÚJD 156/2021 Authorizing the Commissioning of Mochovce Nuclear Plant Unit 3**

Dear Sir or Madam,

thank you for transmitting the decision No. 156/2021 in the administrative procedure in the matter of commissioning of Mochovce unit 3. Three documents were published<sup>1</sup>.

**We appeal the decision No. 156/2021<sup>2</sup> on the following grounds, additional to our appeal dated 28<sup>th</sup> May 2021, and demand that it and all related authorizations shall be suspended.**

**We received the following information and would like to raise it as our objection in the ongoing procedure and ask for information on test results confirmed by independent experts:**

Pre dodávku stabilného hasiaceho zariadenia bol pre 3 a 4 blok jadrovej elektrárne Mochovce vybraný dodávateľ EUSEBI IMPIANTI – Taliansko. Táto spoločnosť nemala vhodné hlavné komponenty a ich skúšku pre najnepriaznivejšie hasebné úseky systému vodnej hmly.

System vodnej hmly bol navrhnutý podľa iných ako slovenských predpisov. Hasiči v slovenskej republike neboli a ani teraz nie sú školený na to aby vedeli posúdiť návrh, hydraulickú kalkuláciu, správnosť montáže a vykonanie testov podľa aplikovaných predpisov pre vodnú hmlu.

Žiadame preto vykonanie testov pre horizontálny, ale aj vertikálny hasiaci úsek s najväčším objemom. Ďalej žiadame vykonanie testov pre horizontálny, ale aj vertikálny hasiaci úsek s najnepriaznivejším hydraulickým výpočtom a to za účasti nezávislých špecialistov na hasenie vodnou hmlou investora a GLOBAL 2000. Súčasťou týchto testov bude aj posúdenie správnosti návrhu, inštalácie, montáže a posúdenie vhodnosti použitých komponentov v testovaných úsekoch a vodnom zdroji.

<sup>1</sup> <https://www.ujd.gov.sk/ujd/www1.nsf/5445d0bff8676fcac1256f1c002c4740/fabc46cbcd898778c12586650024e979?OpenDocument>

<sup>2</sup> [https://www.ujd.gov.sk/ujd/www1.nsf/0/FABC46CBCD898778C12586650024E979/\\$FILE/R156\\_2021\\_Smlm.pdf](https://www.ujd.gov.sk/ujd/www1.nsf/0/FABC46CBCD898778C12586650024E979/$FILE/R156_2021_Smlm.pdf)

**The documents and reports available to us do not prove that the Mochovce unit 3 would be in line with current safety demands and highest safety culture, therefore we appeal decision ÚJD No. 156/2021 for NPP Mochovce 3.**

Yours sincerely

Mag. Agnes Zauner  
[electronic signature]